



eurofins

Confirmation

Eurofins Product Testing A/S confirms that a sample of a floor coating with the name

ROCLAND
supplied by
RCR Production France

showed low VOC contents in a test in accordance with SCAQMD rule 1113 as specified in LEED 2009 credit c4.2 (paints and coatings).
VOC contents were below the limit value specified as 100 grams VOC minus water per liters for floor coatings.

The test has been performed in April 2013, see test report no. G20256A.

Volatiles content was calculated by Eurofins.
Water content was given by the client.
Content of exempt compounds was set to zero.
Solids content was determined by Eurofins.

According to manufacturer the product group ROCLAND contains following products:

QUALIROC / QUALIDUR / QUALIDUR HP / QUALITOP MASTER / QUALITOP MILLENIUM / QUALITOP TERRAZZO / QUALITOP METAL / QUALITOP METAL HP

With this confirmation, use of the tested product may qualify for fulfilment of LEED 2009 credit EQ c4.2 (paints and coatings).

30 May 2017

Morten Sielemann
Analytical Chemist

Eurofins Product Testing A/S
Smedeskovevej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com