



eurofins

# Confirmation

Eurofins Product Testing A/S confirms that a sample of a floor coating with the name

**ROC SEAL**  
supplied by  
**PLACEO**

showed low VOC contents in a test in accordance with SCAQMD rule 1113 as specified in LEED 2009 credit c4.2 (paints and coatings).  
VOC contents were below the limit value specified as 100 grams VOC minus water per liters for floor coatings.

The test has been performed in April 2013, see test report no. G20256C.

Volatiles content was calculated by Eurofins.  
Water content was given by the client.  
Content of exempt compounds was set to zero.  
Solids content was determined by Eurofins.

**With this confirmation, use of the tested product may qualify for fulfilment of LEED 2009 credit EQ c4.2 (paints and coatings).**

---

06 June 2013

---

Thomas Neuhaus  
Head of product emission test centre

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)