



检测报告编号: 2012J20-30-102021
Test report series No.

SHANGHAI INSTITUTE OF MEASUREMENT AND TESTING TECHNOLOGY
NATIONAL CENTER OF MEASUREMENT AND TEST FOR EAST CHINA
NATIONAL CENTER OF TESTING TECHNOLOGY, SHANGHAI

TEST REPORT

上海市计量测试技术研究院
华东国家计量测试中心
中国上海测试中心

检测报告

委托者
Customer

PLACEO

委托者地址
Address of customer

Z.A. Les Monts du Matin Rue des Lauriers F-26730 La Baume
d'Hostun France

样品名称
Name of sample

地坪耐磨材料表面防静电试块

制造厂
Manufacturer

PLACEO

型号/规格
Model/Specification

Rocland Qualidur HP

样品编号
No. of sample

1#, 2#



批准人/ 职务
Approved by / Functions

童志明 主任

核 验 员
Checked by

童志明

检 测 员
Tested by

陈栋

检测日期
Date for test

2012

年
Year

02

月
Month

10

日
Day

地址: 上海市张衡路 1500 号(总部)
Address No. 1500 Zhangheng Road, Shanghai(headquarters)

电话: 021-38839800
Tel.

传真: 021-50798390
Fax

邮编: 201203
Post Code

客户咨询电话: 800-820-5172
Inquire line

投诉电话: 021-50798262
Tel. for complaint



检测报告编号: 2012J20-30-102021
Test report series No.

SHANGHAI INSTITUTE OF MEASUREMENT AND TESTING TECHNOLOGY
NATIONAL CENTER OF MEASUREMENT AND TEST FOR EAST CHINA
NATIONAL CENTER OF TESTING TECHNOLOGY, SHANGHAI

国家法定计量检定机构计量授权证书号(中心/院): (国)法计(2007)01039号/(2007)01019号
The number of the Certificate of Metrological Authorization to The Legal Metrological Verification Institution is No. (2007) 01039/ No. (2007) 01019

中国合格评定国家认可委员会实验室认可证书号: No. CNAS L0134
The number of the certificate accredited by CNAS is No. L0134

中国国家认证认可监督管理委员会资质认定计量认证证书(CMA)号: 2009000597E
The number of the metrology accreditation certificate by CNCA is No. 2009000597E

本次检测所依据的技术规范(代号、名称):
Reference documents for the test (code, name)

SJ/T 10694-2006 电子产品制造与应用系统防静电检测 通用规范

本次检测所使用的主要测量仪器:
Main measuring instruments used in this test

名称/型号 Name/Model	编号 Number	证书编号/有效期限 Certificate No./Due date	测量范围/准确度等级或 最大允差或不确定度 Measurement range/accuracy class or maximum permissible errors or uncertainty of measurement
便携式万用 高阻计 /800	静-006	2011F12-10-000217 /2012.02.23	湿度<90%RH,10V,10 ³ ~10 ⁴ ,10 ⁸ ~10 ⁹ /±9%,湿度<90%RH,10V,10 ⁴ ~10 ⁸ /±9%, 湿度<90%RH,10V,10 ⁹ ~10 ¹⁰ /±25%,湿度 <90%RH,100V,10 ⁶ ~10 ⁸ /±5%,湿度 <60%RH,100V,10 ⁹ ~10 ¹⁰ /±9%,湿度 <50%RH,100V,10 ¹⁰ ~10 ¹¹ /±15%,湿度 <40%RH,100V,10 ¹¹ ~10 ¹² /±25%

检测地点及环境条件:
Location and environmental condition for the test

地点: 上海市宜山路 716 号环境性能实验室
Location

温度: 20 °C; 湿度: 60 %RH; 其它: /
Ambient temperature Relative humidity Others

检测结果/说明:
Results of test and additional explanation

所测项目的结果符合 SJ/T 10694-2006 的相关要求(见续页)
(测试日期: 2012.02.10)

本报告提供的结果仅对本次被测的样品有效。
The data are valid only for the sample(s).

检测结果/说明 (续页):

Results of test and additional explanation (continued page)

1. 点对点电阻测试

检测项目	技术要求	测试条件及现象描述		结果判定
		1#样块	2#样块	
点对点电阻	$1.0 \times 10^4 \Omega \sim 1.0 \times 10^{10} \Omega$	$1.56 \times 10^6 \Omega$	$1.62 \times 10^6 \Omega$	符合
		$1.91 \times 10^6 \Omega$	$2.35 \times 10^6 \Omega$	
		$1.74 \times 10^6 \Omega$	$3.01 \times 10^6 \Omega$	
		$1.90 \times 10^6 \Omega$	$1.57 \times 10^6 \Omega$	
		$1.75 \times 10^6 \Omega$	$1.40 \times 10^6 \Omega$	

测试仪器 (测试日期 2012.02.10)

名称/型号	编号	有效期
便携式万用高阻计 / 800	静-006	2012.02.23

测试照片

1#样块:



检测结果/说明 (续页):

Results of test and additional explanation (continued page)

2#样块:



检测结果内容结束

上海计量测试